

STAT

SEP 8 1953

MEMORANDUM FOR: Acting Deputy Director (Administration)

SUBJECT: Facilities for [REDACTED]

REFERENCE: Memorandum for the Acting Deputy Director (Administration), dated 26 August 1953, subject: Facilities for the [REDACTED]

STAT


STAT

1. By reference above, a project outlined for additional facilities for the [REDACTED] was transmitted to the Acting Deputy Director (Administration).

2. The requirements for these facilities were reviewed on 4 September 1953 with the DDCI, the DD/A, the Assistant Director for Communications, the Chief of Logistics, the Chief of Technical Operations/TSS, and other representatives. Certain questions were raised concerning the power being made available to the Communications Engineering facility and the requirement for air conditioning in the TSS shop area. The areas in question have been reviewed by this office and the following information is submitted:

a. The estimates for the Communication Engineering building as submitted contained a requirement for three-phase electricity in that building.

b. Elimination of air conditioning in one of the three shop areas in the TSS facility will result in an initial saving of only \$500.00. Should air conditioning be eliminated in one of the shop areas, a five ton air conditioning unit would be required in lieu of a 7½ ton unit for the three areas, the difference in cost being approximately \$500.00. Installation costs will be approximately the same in both instances.


JAMES A. GARRISON
Chief of Logistics

LO/SD;ACC:mt (8 Sept. 1953)

Distribution:

- 1 - Log. ✓
- 1 - Supply Div.

3700